



#100-1617

HEALTH, SAFETY & RISK MANAGEMENT
 Michael O'Rourke
 Program Administrator

175 Route 32 North • New Paltz, NY 12561
 Telephone: 845-255-1400 • Facsimile: 845-255-3826
 Email: morourke@ulsterboces.org



Environmental Hygiene Report

Attn: Dr. Charles Khoury
 District Superintendent
 Ulster Board of Cooperative Educational Services
 175 Route 32 North, New Paltz, NY 12561
 Prepared by: Michael O'Rourke, RPIH – No. 0500399

Location(s)	Career & Technical Center
Project No.	100-1617
Site Visit(s)	October 16, 2016
Report Date	November 21, 2016
Investigator(s)	Michael O'Rourke

Ulster County BOCES Health, Safety & Risk Management does not assert that all potential health or safety hazards at this site were evaluated during this survey. This survey is strictly limited to that which is identified in the Project Scope of the report.

BRINGING ULSTER COUNTY SCHOOLS TOGETHER TO ENHANCE TEACHING & LEARNING

Ellenville Central Schools • Highland Central Schools • Kingston City Schools • New Paltz Central Schools •
 Onteora Central Schools • Rondout Valley Central Schools • Saugerties Central Schools • Walkkill Central Schools

TABLE OF CONTENTS

Executive Summary	1
Project Scope	1
Materials & Methods	1
Results Summary	2
Discussion	2
Comments & Recommendations	2
References	3
Appendix	Laboratory Report(s)

Author's Note: Parenthetical numerals at the end of a sentence reference the work with the corresponding notation in the **References** section. *Please read this report in its entirety, including any attached appendices, to fully understand this investigation.*

Executive Summary

Per the requirements of Subpart 67-4: Lead Testing in School Drinking Water, we sampled water outlets at the Ulster BOCES Career & Technical Center, on October 16, 2016. The regulation defines a water outlet as one that is currently or may potentially be used for cooking or drinking. We identified a total of 54 such water outlets in the building. There were five other locations sampled in this facility using the DOH's protocol prior to the enactment of the law. Of these 59 locations, zero exceeded the 15 parts per billion (ppb) action level. Per 67-4.4, there are no further actions required at this time. A copy of this report will be forwarded to the Ulster County Health Department.

Project Scope

Identify appropriate potable water sampling locations and collect samples from plumbing fixtures at the Ulster BOCES Career & Technical Center, for analysis for lead content. Review the data and information and prepare a written report for the Ulster BOCES administration.

Materials & Methods

All samples were collected from the type of plumbing fixtures where potable water is commonly drawn using the NYSDOH protocol. First-draw samples for lead were collected after the water had sat in the pipes for at least eight hours. All samples were collected in 250 ml containers provided by EnviroTest Laboratories in Newburgh, NY. The samples were returned to the laboratory two days after sampling for analysis per the lab's directives. EnviroTest is NYS ELAP-approved (#10142) for potable and non-potable water analysis.

Results Summary

All sample results and other data were reported to the administration of the local educational agency (LEA) via phone, fax, or e-mail as they became available to our department. **See Appendix for full laboratory reports.**

Water Samples that Exceeded Action Level

Career & Technical Center

Sample	Location	Result (ppb)
---	No Samples Above the Action Level	---

Discussion

In order to be used as healthful fluid for human consumption, water must be free from organisms that are capable of causing disease and from minerals and organic substances that could produce adverse physiological effects. (1) The Safe Drinking Water Act sets maximum contaminant levels (MCLs) for numerous contaminants. These include various inorganic, volatile organic, and synthetic organic compounds. Public water systems are required to do initial and periodic testing of their source water.

Comments & Recommendations

Per the requirements of Subpart 67-4: Lead Testing in School Drinking Water, we sampled water outlets at the Ulster BOCES Career & Technical Center, on October 16, 2016. This was 15 days prior to the October 31, 2016 deadline for Grades 6 – 12 school buildings. The regulation defines a water outlet as one that is currently or may potentially be used for cooking or drinking. We identified a total of 54 such water outlets in the building. There were five other locations sampled in this facility using the DOH's protocol prior to the enactment of the law. Of these 59 locations, zero exceeded the 15 parts per billion (ppb) action level. Per 67-4.4, there are no further actions required at this time. A copy of this report will be forwarded to the Ulster County Health Department.

References

1. **American Water Works Association:** *Water Quality and Treatment*. New York, NY: McGraw-Hill, 1990
2. **Bailey, R.A. et. al.:** *Chemistry of the Environment*. New York, NY: Academic Press, 1978.
3. **USEPA:** *3Ts for Reducing Lead in Drinking Water in Schools*. Washington, DC: USEPA, 2006.

APPENDIX

Laboratory Report(s)

ANALYTICAL REPORT

Job Number: 420-112139-1
SDG Number: Ulster BOCES - CTC
Job Description: Ulster BOCES

For:
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Attention: Michael O'Rourke



Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
11/17/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-112139-1
SDG Number: Ulster BOCES - CTC

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Ulster BOCES

Job Number: 420-112139-1
SDG Number: Ulster BOCES - CTC

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Palentino, Gus J	GJP
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112139-1
SDG Number: Ulster BOCES - CTC

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112139-1	01- West Side Men's TR Sink Faucet	Drinking Water	10/16/2016 0824	10/21/2016 1000
420-112139-2	02-West Side Women's TR Left Sink Faucet	Drinking Water	10/16/2016 0826	10/21/2016 1000
420-112139-3	03-West Side Women's TR Right Sink Faucet	Drinking Water	10/16/2016 0826	10/21/2016 1000
420-112139-4	04-Water Fountain Room 901	Drinking Water	10/16/2016 0833	10/21/2016 1000
420-112139-5	05-Left Sink Faucet Room 901	Drinking Water	10/16/2016 0834	10/21/2016 1000
420-112139-6	06-Right Sink Faucet Room 901	Drinking Water	10/16/2016 0835	10/21/2016 1000
420-112139-7	07-SW Side Women's TR Sink Faucet	Drinking Water	10/16/2016 0836	10/21/2016 1000
420-112139-8	08-SW Side Men's TR Sink Faucet	Drinking Water	10/16/2016 0839	10/21/2016 1000
420-112139-9	09-Left Sink Faucet Room 902	Drinking Water	10/16/2016 0840	10/21/2016 1000
420-112139-10	10-Right Sink Faucet Room 902	Drinking Water	10/16/2016 0841	10/21/2016 1000
420-112139-11	11-TR Sink Faucet Room 902	Drinking Water	10/16/2016 0843	10/21/2016 1000
420-112139-12	12-SE Side Uni-Sex TR Sink Faucet	Drinking Water	10/16/2016 0846	10/21/2016 1000
420-112139-13	13-SE Women's TR Sink Faucet	Drinking Water	10/16/2016 0847	10/21/2016 1000
420-112139-14	14-Room 904 Kitchen Sink Faucet	Drinking Water	10/16/2016 0854	10/21/2016 1000
420-112139-15	15-Room 905 Sink Faucet	Drinking Water	10/16/2016 0855	10/21/2016 1000
420-112139-16	16-Room 602 Left Sink Faucet	Drinking Water	10/16/2016 0858	10/21/2016 1000
420-112139-17	17-Room 602 Right Sink Faucet	Drinking Water	10/16/2016 0858	10/21/2016 1000
420-112139-18	18-TR Adjacent Room 602 Sink Faucet	Drinking Water	10/16/2016 0900	10/21/2016 1000
420-112139-19	19-Health Office TR Sink Faucet	Drinking Water	10/16/2016 0901	10/21/2016 1000
420-112139-20	20-Room 600 3-Bay Left Sink Faucet	Drinking Water	10/16/2016 0905	10/21/2016 1000
420-112139-21	21-Room 600 3-Bay Right Sink Faucet	Drinking Water	10/16/2016 0906	10/21/2016 1000
420-112139-22	22-Room 400A Sink Faucet	Drinking Water	10/16/2016 0920	10/21/2016 1000
420-112139-23	23-Room 400A Toilet room Sink Faucet	Drinking Water	10/16/2016 0921	10/21/2016 1000
420-112139-24	24-Room 400B Sink Faucet	Drinking Water	10/16/2016 0923	10/21/2016 1000
420-112139-25	25-Room 208 Sink Faucet	Drinking Water	10/16/2016 0926	10/21/2016 1000
420-112139-26	26-NW Men'sTR Left Sink Faucet	Drinking Water	10/16/2016 0930	10/21/2016 1000
420-112139-27	27-NW Men's TR Right Sink Faucet	Drinking Water	10/16/2016 0931	10/21/2016 1000

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112139-1
SDG Number: Ulster BOCES - CTC

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112139-28	28-Women's TR Sink Faucet Across from Main Office	Drinking Water	10/16/2016 0935	10/21/2016 1000
420-112139-29	29-701 NE Handwashing Sink Faucet	Drinking Water	10/16/2016 0943	10/21/2016 1000
420-112139-30	30-701 NE 3-Bay Left Sink Faucet	Drinking Water	10/16/2016 0943	10/21/2016 1000
420-112139-31	31-701 NE 3-Bay Right Sink Faucet	Drinking Water	10/16/2016 0944	10/21/2016 1000
420-112139-32	32-701 SE 1-Bay Sink Faucet	Drinking Water	10/16/2016 0946	10/21/2016 1000
420-112139-33	33-701 SE Handwashing Sink Faucet	Drinking Water	10/16/2016 0946	10/21/2016 1000
420-112139-34	34-701 SE 3-Bay Left Sink Faucet	Drinking Water	10/16/2016 0949	10/21/2016 1000
420-112139-35	35-701 SE 3-bay Right Sink Faucet	Drinking Water	10/16/2016 0949	10/21/2016 1000
420-112139-36	36-701 Cleavland Pot Filler South Side	Drinking Water	10/16/2016 0952	10/21/2016 1000
420-112139-37	37-701 SW 3-Bay Left Sink Faucet	Drinking Water	10/16/2016 0955	10/21/2016 1000
420-112139-38	38-701 SW 3-Bay Right Sink Faucet	Drinking Water	10/16/2016 0955	10/21/2016 1000
420-112139-39	39-701 SW Handwashing Sink Faucet	Drinking Water	10/16/2016 0957	10/21/2016 1000
420-112139-40	40-701 Cleavland Pot Filler Center	Drinking Water	10/16/2016 0959	10/21/2016 1000
420-112139-41	41-701 Center 1-bay Sink Faucet	Drinking Water	10/16/2016 1000	10/21/2016 1000
420-112139-42	42-701 Center handwashing Sink Faucet	Drinking Water	10/16/2016 1001	10/21/2016 1000
420-112139-43	43-Room 702 Sink Faucet	Drinking Water	10/16/2016 1005	10/21/2016 1000
420-112139-44	44-Room 300 Sink Faucet	Drinking Water	10/16/2016 1013	10/21/2016 1000
420-112139-45	45-Room 310 Left Sink Faucet	Drinking Water	10/16/2016 1014	10/21/2016 1000
420-112139-46	46-Room 310 Right Sink Faucet	Drinking Water	10/16/2016 1015	10/21/2016 1000
420-112139-47	47-Room 310 TR Sink Faucet	Drinking Water	10/16/2016 1015	10/21/2016 1000
420-112139-48	48-Room 400B TR Left Sink Faucet	Drinking Water	10/16/2016 1041	10/21/2016 1000
420-112139-49	49-Room 400B TR Right Sink Faucet	Drinking Water	10/16/2016 1043	10/21/2016 1000
420-112139-50	50-Room 400A hair Station Sink Faucet #1	Drinking Water	10/16/2016 1048	10/21/2016 1000
420-112139-51	51-Room 400A Hair Station Sink Faucet #2	Drinking Water	10/16/2016 1048	10/21/2016 1000
420-112139-52	52-Room 400A Hair Station Sink Faucet #3	Drinking Water	10/16/2016 1048	10/21/2016 1000
420-112139-53	53-Room 400A Hair Station Sink Faucet #4	Drinking Water	10/16/2016 1048	10/21/2016 1000
420-112139-54	54-Room 400A Hair Station Sink Faucet #5	Drinking Water	10/16/2016 1048	10/21/2016 1000

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 01- West Side Men's TR Sink Faucet
Lab Sample ID: 420-112139-1

Date Sampled: 10/16/2016 0824
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1313	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 02-West Side Women's TR Left Sink Faucet
Lab Sample ID: 420-112139-2

Date Sampled: 10/16/2016 0826
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1315	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 03-West Side Women's TR Right Sink Faucet
Lab Sample ID: 420-112139-3

Date Sampled: 10/16/2016 0826
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1317	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 04-Water Fountain Room 901
Lab Sample ID: 420-112139-4

Date Sampled: 10/16/2016 0833
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed: 11/14/2016 1403	
Prep Method: 200				Date Prepared: 11/14/2016 0930	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 05-Left Sink Faucet Room 901
Lab Sample ID: 420-112139-5

Date Sampled: 10/16/2016 0834
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1319	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	3.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 06-Right Sink Faucet Room 901
Lab Sample ID: 420-112139-6

Date Sampled: 10/16/2016 0835
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1321	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.7	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 07-SW Side Women's TR Sink Faucet
Lab Sample ID: 420-112139-7

Date Sampled: 10/16/2016 0836
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1323	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	2.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 08-SW Side Men's TR Sink Faucet
Lab Sample ID: 420-112139-8

Date Sampled: 10/16/2016 0839
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1324	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 09-Left Sink Faucet Room 902
Lab Sample ID: 420-112139-9

Date Sampled: 10/16/2016 0840
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1326	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 10-Right Sink Faucet Room 902
Lab Sample ID: 420-112139-10

Date Sampled: 10/16/2016 0841
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1332	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	2.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 11-TR Sink Faucet Room 902
Lab Sample ID: 420-112139-11

Date Sampled: 10/16/2016 0843
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1334	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	4.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 12-SE Side Uni-Sex TR Sink Faucet
Lab Sample ID: 420-112139-12

Date Sampled: 10/16/2016 0846
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1336	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.7	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 13-SE Women's TR Sink Faucet
Lab Sample ID: 420-112139-13

Date Sampled: 10/16/2016 0847
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1337	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	2.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 14-Room 904 Kitchen Sink Faucet
Lab Sample ID: 420-112139-14

Date Sampled: 10/16/2016 0854
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1339	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 15-Room 905 Sink Faucet
Lab Sample ID: 420-112139-15

Date Sampled: 10/16/2016 0855
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1341	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 16-Room 602 Left Sink Faucet
Lab Sample ID: 420-112139-16

Date Sampled: 10/16/2016 0858
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1343	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	2.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 17-Room 602 Right Sink Faucet
Lab Sample ID: 420-112139-17

Date Sampled: 10/16/2016 0858
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1345	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 18-TR Adjacent Room 602 Sink Faucet
Lab Sample ID: 420-112139-18

Date Sampled: 10/16/2016 0900
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1347	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 19-Health Office TR Sink Faucet
Lab Sample ID: 420-112139-19

Date Sampled: 10/16/2016 0901
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1349	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 20-Room 600 3-Bay Left Sink Faucet
Lab Sample ID: 420-112139-20

Date Sampled: 10/16/2016 0905
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1354	
Prep Method: 200			Date Prepared:	11/12/2016 1600	
Pb	1.7	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 21-Room 600 3-Bay Right Sink Faucet
Lab Sample ID: 420-112139-21

Date Sampled: 10/16/2016 0906
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1356	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 22-Room 400A Sink Faucet
Lab Sample ID: 420-112139-22

Date Sampled: 10/16/2016 0920
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1404	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 23-Room 400A Toilet room Sink Faucet
Lab Sample ID: 420-112139-23

Date Sampled: 10/16/2016 0921
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1406	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 24-Room 400B Sink Faucet
Lab Sample ID: 420-112139-24

Date Sampled: 10/16/2016 0923
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1407	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 25-Room 208 Sink Faucet
Lab Sample ID: 420-112139-25

Date Sampled: 10/16/2016 0926
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1409	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 26-NW Men'sTR Left Sink Faucet
Lab Sample ID: 420-112139-26

Date Sampled: 10/16/2016 0930
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1411	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 27-NW Men's TR Right Sink Faucet
Lab Sample ID: 420-112139-27

Date Sampled: 10/16/2016 0931
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1417	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 28-Women's TR Sink Faucet Across from Main
Lab Sample ID: 420-112139-28

Date Sampled: 10/16/2016 0935
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1419	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	2.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 29-701 NE Handwashing Sink Faucet
Lab Sample ID: 420-112139-29

Date Sampled: 10/16/2016 0943
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1421	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 30-701 NE 3-Bay Left Sink Faucet
Lab Sample ID: 420-112139-30

Date Sampled: 10/16/2016 0943
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1423	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 31-701 NE 3-Bay Right Sink Faucet
Lab Sample ID: 420-112139-31

Date Sampled: 10/16/2016 0944
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1424	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 32-701 SE 1-Bay Sink Faucet
Lab Sample ID: 420-112139-32

Date Sampled: 10/16/2016 0946
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1426	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 33-701 SE Handwashing Sink Faucet
Lab Sample ID: 420-112139-33

Date Sampled: 10/16/2016 0946
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1428	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 34-701 SE 3-Bay Left Sink Faucet
Lab Sample ID: 420-112139-34

Date Sampled: 10/16/2016 0949
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1430	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 35-701 SE 3-bay Right Sink Faucet
Lab Sample ID: 420-112139-35

Date Sampled: 10/16/2016 0949
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1432	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 36-701 Cleavland Pot Filler South Side
Lab Sample ID: 420-112139-36

Date Sampled: 10/16/2016 0952
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1434	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 37-701 SW 3-Bay Left Sink Faucet
Lab Sample ID: 420-112139-37

Date Sampled: 10/16/2016 0955
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1440	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	2.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 38-701 SW 3-Bay Right Sink Faucet
Lab Sample ID: 420-112139-38

Date Sampled: 10/16/2016 0955
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1441	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 39-701 SW Handwashing Sink Faucet
Lab Sample ID: 420-112139-39

Date Sampled: 10/16/2016 0957
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/13/2016 1443	
Prep Method: 200			Date Prepared:	11/12/2016 1655	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 40-701 Cleavland Pot Filler Center
Lab Sample ID: 420-112139-40

Date Sampled: 10/16/2016 0959
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1042	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	4.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 41-701 Center 1-bay Sink Faucet
Lab Sample ID: 420-112139-41

Date Sampled: 10/16/2016 1000
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1049	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 42-701 Center handwashing Sink Faucet
Lab Sample ID: 420-112139-42

Date Sampled: 10/16/2016 1001
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1051	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 43-Room 702 Sink Faucet
Lab Sample ID: 420-112139-43

Date Sampled: 10/16/2016 1005
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1053	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 44-Room 300 Sink Faucet
Lab Sample ID: 420-112139-44

Date Sampled: 10/16/2016 1013
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed: 11/14/2016 1055	
Prep Method: 200				Date Prepared: 11/13/2016 1220	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 45-Room 310 Left Sink Faucet
Lab Sample ID: 420-112139-45

Date Sampled: 10/16/2016 1014
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1057	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 46-Room 310 Right Sink Faucet
Lab Sample ID: 420-112139-46

Date Sampled: 10/16/2016 1015
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1103	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 47-Room 310 TR Sink Faucet
Lab Sample ID: 420-112139-47

Date Sampled: 10/16/2016 1015
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1104	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 48-Room 400B TR Left Sink Faucet
Lab Sample ID: 420-112139-48

Date Sampled: 10/16/2016 1041
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1106	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 49-Room 400B TR Right Sink Faucet
Lab Sample ID: 420-112139-49

Date Sampled: 10/16/2016 1043
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1108	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 50-Room 400A hair Station Sink Faucet #1
Lab Sample ID: 420-112139-50

Date Sampled: 10/16/2016 1048
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1110	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 51-Room 400A Hair Station Sink Faucet #2
Lab Sample ID: 420-112139-51

Date Sampled: 10/16/2016 1048
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1112	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 52-Room 400A Hair Station Sink Faucet #3
Lab Sample ID: 420-112139-52

Date Sampled: 10/16/2016 1048
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1114	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 53-Room 400A Hair Station Sink Faucet #4
Lab Sample ID: 420-112139-53

Date Sampled: 10/16/2016 1048
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1115	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112139-1
Sdg Number: Ulster BOCES - CTC

Client Sample ID: 54-Room 400A Hair Station Sink Faucet #5
Lab Sample ID: 420-112139-54

Date Sampled: 10/16/2016 1048
Date Received: 10/21/2016 1000
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/14/2016 1117	
Prep Method: 200			Date Prepared:	11/13/2016 1220	
Pb	1.0 U	ug/L	1.0	1.0	1.0

DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:
Sdg Number: Ulster BOCES - CTC

Lab Section	Qualifier	Description
Metals	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Ulster BOCES

Job Number:

Sdg Number: Ulster BOCES - CTC

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalein Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Ulster BOCES

Job Number:

Sdg Number: Ulster BOCES - CTC

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

REPORT# (Lab Use Only)

112139

EnviroTest Laboratories
 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Ulster BOCES - CTC		PROJECT NO.	PROJECT LOCATION CTC	MATRIX TYPE	REQUIRED ANALYSES							PAGE 1 of 1	
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	OTHER SPECIFY	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
CLIENT (SITE) PM M.O'Rourke - results to morourke@ulsterbooces.org		CLIENT PHONE 845-338-8317	CLIENT FAX	COMPOSITE (C) OR GRAB (G) INDICATE	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
CLIENT NAME Ulster BOCES				AQUEOUS (WATER)	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
CLIENT ADDRESS 175 Route 32N, New Palz, NY 12561				SOLID OR SEMISOLID	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
COMPANY CONTRACTING THIS WORK (IF APPLICABLE)				OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
SAMPLE IDENTIFICATION				OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
DATE	TIME			OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
10/16/2016	8:24	01 - West Side Men's TR Sink Faucet		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:26	02 - West Side Women's TR Left Sink Faucet		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:26	03 - West Side Women's TR Right Sink Faucet		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:33	04 - Water fountain Room 901		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:34	05 - Left Sink Faucet Room 901		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:35	06 - Right Sink Faucet Room 901		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:36	07 - SW Side Women's TR Sink Faucet		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:39	08 - SW Side Men's TR Sink Faucet		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:40	09 - Left Sink Faucet Room 902		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:41	10 - Right Sink Faucet Room 902		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:43	11 - TR Sink Faucet Room 902		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:46	12 - SE Side Uni-Sex TR Sink Faucet		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
	8:47	13 - SE Women's TR Sink Faucet		OTHER SPECIFY	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	
RELINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	NUMBER OF CONTAINERS SUBMITTED							REMARKS	
[Signature]		UCB	10/16/16	1048	1	1	1	1	1	1	1	1	Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	1	1	1	1	1	1	1	1	Lead (DW 200.8)
[Signature]		UCB	10/21/16	1000	1	1	1	1	1	1	1	1	Lead (DW 200.8)
RECEIVED FOR LABORATORY BY: (SIGNATURE)		DATE	TIME	CUSTODY INTACT	RECEIVED BY: (SIGNATURE)							REMARKS	
[Signature]		10/21/16	1000	NO	[Signature]							Lead (DW 200.8)	
LABORATORY REMARKS:		ICE (Y/N)	PH	CL2	RECEIVED BY: (SIGNATURE)							REMARKS	
[Signature]			21.9°C		[Signature]							Lead (DW 200.8)	

IR # 3

EnviroTest Laboratories
 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Ulster BOCES - CTC		PROJECT NO.	PROJECT LOCATION CTC	MATRIX TYPE	REQUIRED ANALYSES					PAGE 1 of	2		
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	TURNAROUND TIME
CLIENT (SITE) PW M. O'Rourke - results to morourke@ulsterboces.org		CLIENT PHONE 845-338-8317	CLIENT FAX										NORMAL
CLIENT NAME Ulster BOCES													QUICK
CLIENT ADDRESS 175 Route 32N, New Paltz, NY 12561													VERBAL
COMPANY CONTRACTING THIS WORK (if applicable)													
SAMPLE		SAMPLE IDENTIFICATION		COMPOSITE (C) OR GRAB (G) INDICATE	NUMBER OF CONTAINERS SUBMITTED			#OF COOLERS			REMARKS		
DATE	TIME				1	1	1	1	1	1	1	1	Lead (DW 200.8)
10/16/2016	8:54	14 - Room 904 Kitchen Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	8:55	15 - Room 905 Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	8:58	16 - Room 602 Left Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	8:58	17 - Room 602 Right Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	9:00	18 - TR Adjacent Room 602 Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	9:01	19 - Health Office TR Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	9:05	20 - Room 600 3-Bay Left Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	9:06	21 - Room 600 3-Bay Right Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	9:20	22 - Room 400A Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	9:21	23 - Room 400A Toilet Room Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	9:23	24 - Room 400B Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	9:26	25 - Room 208 Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
	9:30	26 - NW Men's TR Left Sink Faucet			1	1	1	1	1	1	1	1	Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME	
	U CB	10/16/16	1048										
	U CB	10/21/16	1000										
RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	COOLER Temp (C)	LABORATORY REMARKS	ICE (Y/N)	CL1	CL2	Revised by				
Q Elmendorf ETR	10/21/16	1000	YES	21.9°C									

IR#3

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

REPORT# (Lab Use Only)

112139

Lab Name
Address & Phone

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Ulster BOCES - CTC		PROJECT NO. P.O. NUMBER	PROJECT LOCATION CTC	MATRIX TYPE	REQUIRED ANALYSES						PAGE 1 of 3		
ENVIROTEST PROJECT MANAGER Debra Bayer		CLIENT PHONE 845-338-8317	TOWN	OTHER SPECIFY	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	TURNAROUND TIME
CLIENT (SITE) PM M. O'Rourke - results to morourke@ulsterboces.org		CLIENT FAX		COMPOSITE (C) OR GRAB (G) INDICATE									NORMAL
CLIENT NAME Ulster BOCES				AQUEOUS (WATER)									QUICK
CLIENT ADDRESS 175 Route 32N, New Paltz, NY 12561				SAMPLE IDENTIFICATION									VERBAL
COMPANY CONTRACTING THIS WORK (IF APPLICABLE)				DATE	TIME	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME	REMARKS		
				10/16/2016	9:31	27 - NW Men's TR Right Sink Faucet			1		Lead (DW 200.8)		
				9:35		28 - Women's TR Sink Faucet Across From Main Office			1		Lead (DW 200.8)		
				9:43		29 - 701 NE Handwashing Sink Faucet			1		Lead (DW 200.8)		
				9:43		30 - 701 NE 3-Bay Left Sink Faucet			1		Lead (DW 200.8)		
				9:44		31 - 701 NE 3-Bay Right Sink Faucet			1		Lead (DW 200.8)		
				9:46		32 - 701 SE 1-Bay Sink Faucet			1		Lead (DW 200.8)		
				9:46		33 - 701 SE Handwashing Sink Faucet			1		Lead (DW 200.8)		
				9:49		34 - 701 SE 3-Bay Left Sink Faucet			1		Lead (DW 200.8)		
				9:49		35 - 701 SE 3-Bay Right Sink Faucet			1		Lead (DW 200.8)		
				9:52		36 - 701 Cleveland Pot Filler South Side			1		Lead (DW 200.8)		
				9:55		37 - 701 SW 3-Bay Left Sink Faucet			1		Lead (DW 200.8)		
				9:55		38 - 701 SW 3-Bay Right Sink Faucet			1		Lead (DW 200.8)		
				9:57		39 - 701 SW Handwashing Sink Faucet			1		Lead (DW 200.8)		
REINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME						
SAMPLED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME						
REINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME						
RECEIVED FOR LABORATORY BY: (SIGNATURE)		DATE	TIME	CUSTODY INTACT YES NO	Cooler Temp (C)	LABORATORY REMARKS		ICE (Y/N)	CL1	CL2	Revised by		
Debra Bayer		10/16/16	1000	YES	21.9°C								

IR # 3

112129

EnviroTest Laboratories
 Address & Phone 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Ulster BOCES - CTC		PROJECT NO	PROJECT LOCATION CTC	MATRIX TYPE		REQUIRED ANALYSES		PAGE 1 of 4
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	ADQUEOUS (WATER)		40ml Vials HCl	Liter Amber HCl	TURNAROUND TIME
CLIENT (SITE) / PW M. O'Rourke - results to morourke@ulsterbooces.org		CLIENT PHONE 845-338-8317	CLIENT FAX	COMPOSITE (C) OR GRAB (G) / WASTE		250ml Plastic Nitric Acid	Liter Plastic	NORMAL
CLIENT NAME Ulster BOCES				SOLID OR SEMISOLID		250ml Plastic Sulfuric Acid	250ml Plastic	QUICK
CLIENT ADDRESS 175 Route 32N, New Palz, NY 12561				OTHER SPECIFY		Other	Other	VERBAL
COMPANY CONTRACTING THIS WORK (IF APPLICABLE)								
SAMPLE IDENTIFICATION								#OF COOLERS
DATE	TIME							
10/16/2016	9:59	40 - 701 Cleveland Pot Filler Center						Lead (DW 200.8)
	10:00	41 - 701 Center 1-Bay Sink Faucet						Lead (DW 200.8)
	10:01	42 - 701 Center Handwashing Sink Faucet						Lead (DW 200.8)
	10:05	43 - Room 702 Sink Faucet						Lead (DW 200.8)
	10:13	44 - Room 300 Sink Faucet						Lead (DW 200.8)
	10:14	45 - Room 310 Left Sink Faucet						Lead (DW 200.8)
	10:15	46 - Room 310 Right Sink Faucet						Lead (DW 200.8)
	10:15	47 - Room 310 TR Sink Faucet						Lead (DW 200.8)
	10:41	48 - Room 400B TR Left Sink Faucet						Lead (DW 200.8)
	10:43	49 - Room 400B TR Right Sink Faucet						Lead (DW 200.8)
	10:48	50 - Room 400A Hair Station Sink Faucet #1						Lead (DW 200.8)
	10:48	51 - Room 400A Hair Station Sink Faucet #2						Lead (DW 200.8)
	10:48	52 - Room 400A Hair Station Sink Faucet #3						Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)		COMP/DATE	TIME
<i>[Signature]</i>		UCB	10/16/16	1048	<i>[Signature]</i>		COMP/DATE	TIME
RELINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)		COMP/DATE	TIME
<i>[Signature]</i>		UCB	10/21/16	1000	<i>[Signature]</i>		COMP/DATE	TIME
RECEIVED FOR LABORATORY BY: (SIGNATURE)		DATE	TIME	CUSTODY INTACT	COOLER TEMP(C)	LABORATORY REMARKS: ICE Y ___ N ___ PH ___ CL2 ___ Reviewed by		
<i>[Signature]</i>		10/21/16	1000	NO	21.9°C	IR #3		

EnviroTest Laboratories
 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE Ulster BOCES - CTC	PROJECT NO.	PROJECT LOCATION CTC	MATRIX TYPE	REQUIRED ANALYSES	PAGE 1 of 5
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN		40ml Vials HCl	TURNAROUND TIME
CLIENT (SITE) PM M. O'Rourke - results to morourke@ulsterbooces.org	CLIENT PHONE 845-338-8317	CLIENT FAX		Liter Amber HCl	NORMAL
CLIENT NAME Ulster BOCES				250ml Plastic Nitric Acid	QUICK
CLIENT ADDRESS 175 Route 32N, New Paltz, NY 12561				250ml Plastic Sulfuric Acid	VERBAL
COMPANY CONTRACTING THIS WORK (IF APPLICABLE)				Liter Plastic	
				250ml Plastic	
				Terra Core	
				Other	
				Other	

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED										REMARKS			
			1	1	1	1	1	1	1	1	1	1		1	1	
10/16/2016	10:48	53 - Room 400A Hair Station Sink Faucet #4	1													Lead (DW 200.8)
4	10:48	54 - Room 400A Hair Station Sink Faucet #5	1													Lead (DW 200.8)
			1													Lead (DW 200.8)
			1													Lead (DW 200.8)
			1													Lead (DW 200.8)
			1													Lead (DW 200.8)
			1													Lead (DW 200.8)
			1													Lead (DW 200.8)
			1													Lead (DW 200.8)
			1													Lead (DW 200.8)
			1													Lead (DW 200.8)
			1													Lead (DW 200.8)
			1													Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPANY	DATE	TIME
<i>[Signature]</i>	COMPANY	10/16/16	10:48	<i>[Signature]</i>	COMPANY	10/21/16	10:00
<i>[Signature]</i>	COMPANY	10/21/16	10:00	<i>[Signature]</i>	COMPANY		

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE 10/21/16 TIME 10:00

COOLER TEMP (C) 21.9°C

LABORATORY REMARKS: ICE (Y) N PH 7.1 CL2 PH Revisited by _____

IR # 3

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-112139-1
SDG Number: Ulster BOCES - CTC

Login Number: 112139

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	21.9 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	